

**ATTAR TEST REPORT NUMBER: 11/4775.5**

This document is issued in accordance with NATA's accreditation requirements. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards. Accredited for compliance with ISO/IEC 17025. Accreditation Number: 2735

21 March 2011

Total Pages: 1**OIL-WET RAMP SLIP RESISTANCE**

Job No: M11/4775

| | | |
|--|---|---|
| Prepared for: | Gerflor Australasia Pty Ltd 17 Cato Street HAWTHORN EAST VIC 3123 | |
| Attention: | Jutta Fronert | |
| Test Site: | ATTAR, Unit 12, 134 Springvale Road, Springvale. | |
| Test Date: | 9 March 2011 | |
| Manufacturer: | Gerflor Australasia | |
| Test Specimen, Size & Quantity Received: | H8218704 Tarasafe Ultra 2M Pebble Batch/Roll: 7047242-7322305315, 51x200 cm, 1 off supplied. | |
| Sampling & Direction of Testing: | Sampling conducted by client. Test direction not applicable | |
| Test Personnel: | Steven Potts and Daniel King | |
| Preparation: | Cut and mounted on 1200x600mm particle board for testing. | |
| Joint Width: | N/A | |
| Air Temperature: | 24°C | |
| Test Standard: | AS/NZS 4586 - 2004 Slip resistance classification of new pedestrian surface materials – Appendix D. | |
| Surface Structure : | Structured. | |
| Classification Criteria: (TABLE D3 in AS/NZS 4586- 2004) | Corrected Mean Overall Acceptance Angle | Slip Resistance Assessment Group |
| | 6° to 10° | R9 |
| | Over 10° to 19° | R10 |
| | Over 19° to 27° | R11 |
| | Over 27° to 35° | R12 |
| | Over 35° | R13 |
| Displacement Space: | Not Measured | |
| Displacement Space Assessment Group: | N/A | |
| Mean Overall Acceptance Angle: | 15.5° | |
| Slip Resistance Assessment Group: | R10 | |

These results apply only to the specimens tested and it is recommended that before selection of flooring or paving materials the effect of service conditions, including maintenance procedures and wear on their slip-resistance be checked.

NOTE: Any specimens supplied will be disposed of in two (2) months time, unless otherwise instructed.

ATTAR

Steven Potts
Slip & Engineering Technician
Approved Signatory

This report may not be reproduced except in its entirety.

1