



REACTION TO FIRE CLASSIFICATION REPORT N° 2014/037-2

(English report of classification report RC 2014/037-1)

According to EN 13501-1 (2007) + A1 (2013)

Notification by the French Government to the European Commission
under n° NB 2401

Sponsor :	BALSAN Corbilly Arthon 36330 LE POINCONNET FRANCE
Product name :	Tufted pile carpet 100% polyamide on woven synthetic backing (Update)
Description :	Textile floor coverings (EN 1307 family) (see detailed description in paragraph 2)
Date of issue :	27/01/2021

The indicated classification does not prejudice the conformity of marketed materials with the samples submitted to the tests and under no circumstances, this document should not be considered as type approval or certification of the product in the sense of the L 115-27 article of the consumption's code of the law dated June 3rd 1994.

*The reproduction of this classification report is only authorised in its integral form.
It comprises 5 pages*

1. Introduction

This classification report defines the classification assigned to the above-mentioned product (s) in accordance with the procedures given in the NF EN 13501-1 standard: September 2007 & A1 (2013).

2. Details of classified product**2.1. Product standard**

NF EN 14041 (2005): "Resilient, textile and laminate floor coverings - Essential characteristics".

2.2. Product description

Tufted pile carpet 100% polyamide on woven polypropylene backing (EN 1307 family).

Tested glued over a fibre-cement board classified A1_n or A2_n with a density (1800 ± 200) kg/m³ and thickness (8 ± 2) mm.

Use surface: 100 % polyamide

Nominal mass per unit area : 1300 to 2940 g/m²

Nominal effective pile thickness : 2,2 to 11,0 mm

3. Test reports and tests results in support of this classification**3.1. Tests reports**

Name of laboratory	Name of sponsor	Test report N°	Test method
C.R.E.T.	BALSAN Corbilly Arthon 36330 LE POINCONNET FRANCE	RL 2019/445 (09/07/2019)	NF EN ISO 9239-1

Name of laboratory	Name of sponsor	Test report N°	Test method
C.R.E.T.	BALSAN Corbilly Arthon 36330 LE POINCONNET FRANCE	RL 2017/017 (31/01/2017)	NF EN ISO 9239-1

Name of laboratory	Name of sponsor	Test report N°	Test method
C.R.E.T.	BALSAN Corbilly Arthon 36330 LE POINCONNET FRANCE	RL 2020/686 (06/11/2020)	NF EN ISO 9239-1

3.2. Tests results

Classes of reaction to fire for textile floor coverings, classified without further testing.

Test method	The floorings « VEDETTE DD » - « IDYLLE » - « SUBLIME » meet the requirements of table 2 of the standard EN 14041 and are classified without further testing (CWFT)
NF EN ISO 11925-2	Classification E_n

Test method	Product	Number of tests	Parameters	Results
				Continuous parameters : mean value
NF EN ISO 9239-1	VEDETTE DD (Test report RL 2019/445)	3	Critical heat flux (kW/m²)	9,8
			Smoke (% X min)	23,6

Test method	Product	Number of tests	Parameters	Results
				Continuous parameters : mean value
NF EN ISO 9239-1	IDYLLE (Test report RL 2017/017)	3	Critical heat flux (kW/m²)	4,9
			Smoke (% X min)	273,7

Test method	Product	Number of tests	Parameters	Results
				Continuous parameters : mean value
NF EN ISO 9239-1	SUBLIME (Test report RL 2020/686)	3	Critical heat flux (kW/m²)	8,5
			Smoke (% X min)	144,4

4. Classification and field of application

4.1. Reference of classification

This classification has been carried out in accordance with EN 13501-1 :2007 & A1 (2013).

4.2. Classification

Fire behaviour		Smoke production
C _n	-	s1

Classification : C_n – s1

4.3. Field of application

This classification is valid for the following end use applications :

Glued over fibre-cement A2_n or A1_n.

This classification is valid for the following product parameters :

- A nominal mass per unit area of: 1300 to 2940 g/m²
- A nominal effective pile thickness of : 2,2 to 11,0 mm

The classification of the product family is valid for the following trademarks :

**AQUARELLE TOUCH
AVENUE ROLL
BACCARAT**

BALMORAL
CAPITOL
CARROUSEL
CENTAURE DECO
CONSTELLATION
DESIGN CONCEPT
DUO LES BEST
DUO SYDNEY
EQUINOXE
FEELINGS
FIRST CLASS
FRENCH COUTURE SOFT
GABARDINE
GRAND HOTEL
IDYLLE
INFINI COLORS DD
LES BEST
LES BEST S
LES BEST DESIGN II
LUXE
PILOTE² DD
QUICK DD
RESIDENTIEL DD
SCENARIO
SCRIPT
SERENITE
SIGNATURE
STONE AGE DD
SUBLIME
SWEET DREAMS
SYDNEY
SYDNEY DESIGN
TERRITOIRES
TOP DESIGN 650 SAXONY
TOP DESIGN 650 VELOURS
TOP DESIGN 655
TOP DESIGN 950 SAXONY
TOP DESIGN 1030 SAXONY
TOP DESIGN 1100 SAXONY
TOP DESIGN 1300 SAXONY
TOP DESIGN 620 LOOP
TOP DESIGN 650 VELOURS
TOP DESIGN 1240 LCL
URBANIST DD
VEDETTE DD

5. Limitations

This classification document does not represent type approval or certification of the product.

“The classification assigned to the product in this report is appropriate to a declaration of conformity by the manufacturer within the context of system 3 attestation of conformity and CE marking under the Construction Products Directive.

The manufacturer has made a declaration, which is held on file. This confirms that the products design requires no specific processes, procedures or stages (no addition of flame-retardants, limitation of organic content, or addition of fillers) that are aimed at enhancing the fire performance in order to obtain the classification achieved. As a consequence the manufacturer has concluded that system 3 attestation is appropriate.

The test laboratory has, therefore, played no part in sampling the product for the test, although it holds appropriate references, supplied by the manufacturer, to provide for traceability of the samples tested.”

For the SARL C.R.E.T.
The Technical Director
Marc WELCOMME



End of the classification report