



Decospan nv
Lageweg 33
8930 MENEN
BELGIUM

Your message - reference

-

our reference

PW/278

Gent

2021-01-29

Certification report 21/278

1. Description of the flooring:

Product family	Parky Wood veneered floor covering with surface coating with/without cork bottom-layer
Density	850 kg/m ³ - 900 kg/m ³
Total thickness	7.2 mm – 12.0 mm
Thickness veneer toplayer	0.6 mm

2. Test results:

Classification according to EN 13501-1:2007+A1 (2009)

Class	EN ISO 11925-2 or CWFT (EN 14041 - 2004)	EN ISO 9239-1 (30 min.)
C _{fl}	E _{fl}	heat flux ≥ 4.5 kW/m ²

This report includes 2 pages and may only be reproduced in its entirety. The test results cover the received samples. Centexbel is not responsible for the representativeness of the samples.

Centexbel is a notified body N° 0493 for the European CPR (Construction Products Regulation) and for the European Directive related to Personal Protection Equipment.

CENTEXBEL • textile competence centre • www.centexbel.be

GENT • Technologiepark 70 • BE 9052 Gent • Belgium • phone +32 9 220 41 51 • fax +32 9 220 49 55 • gent@centexbel.be

VAT • BE 0459.218.289 • IBAN • BE 44 2100 4729 6545 • BIC • GEBABEBB



addressee

Decospan nv

our reference

PW/278

Gent

2021-01-29

page

2

3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows:

loose-laid tested on a combustible substrate¹

Cfl - s1

Related commercial names to this product group	Pro 06 Lounge 06 Master 06 Deluxe+ 06 Summit 06 Swing 06
The obtained classification is based on the next test reports	Centexbel: 20.06759.01 dd 2020-12-03 Centexbel: 20.06759.02 dd 2020-12-24
Validity of the certificate	2025-12-02

Petra Wittevrongel
Product Certifier

¹ End use substrates of wood and of classes A1 and A2-s1,d0 (ISO 13238:2010 § 5.2.3)