# **AWTA PRODUCT TESTING**

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400

### **TEST REPORT**

Test Number:

**Issue Date** 

**Print Date** 

25-005447

5/12/2025

9/12/2025

Client: Belgotex NZ

**Sample Description** 

25 Leslie Hills Drive Riccarton, Christchurch

New Zealand


Clients Ref : "Seastride Carpet tiles"

Loop pile carpet tile End Use : Flooring

Nominal Composition: Solution Dyed Nylon with Ecolight PVC Backing

Nominal Mass per Unit Area/Density: 16oz/yd2

Nominal Thickness: 5.6mm



366758 81285 Page 1 of 3

Australian Wool Testing Authority Ltd Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing Accreditation Numbers: 983, 985, and 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.



MICHAEL A. JACKSON B.Sc.(Hons)

Fiona McDonald

# AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400

### **TEST REPORT**

Client: Belgotex NZ Test Number: 25-005447

25 Leslie Hills Drive Issue Date : 5/12/2025 Riccarton, Christchurch Print Date : 9/12/2025

New Zealand

ISO 9239.1:2010 Part 1 Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a

**Radiant Heat Source** 

Date of Sample Arrival 05-12-2025

Date Tested 22-08-2025

Date rected	00 _0_0				
CHF Value	1	2	3	Mean	
Length	4.9	-	-	-	kW/m²
Width	4.7	4.7	4.7	4.7	kW/m²
HF-30 Value	1	2	3	Mean	
Length	4.9	-	-	-	kW/m²
Width	5.3	5.3	4.7	5.1	kW/m²
Smoke Value	1	2	3	Mean	
Length	102	-	-	-	%.min
Width	99	138	106	114	%.min

366758 81285 Page 2 of 3

Australian Wool Testing Authority Ltd Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing Accreditation Numbers: 983, 985, and 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.







Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400

### **TEST REPORT**

Client: Belgotex NZ

25 Leslie Hills Drive Riccarton, Christchurch

New Zealand

**Test Number** : 25-005447

**Issue Date** : 5/12/2025

Print Date :

9/12/2025

Yes

Observations:

Melting

The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test, they are not intended to be sole criterion for assessing the potential fire hazard of the product in use.

Sample was conditioned in accordance with BSEN 13238:2010 at a temperature of 23±2°C and relative humidity of 50±5% for a minimum of 48 hours prior to testing.

Results in accordance with section 9.4 have not been included in the report. They are available upon request.

Each specimen was adhered to a substrate of 6mm thick fibre reinforced cement board using Roberts 656 adhesive and clamped prior to testing.

366758 81285 Page 3 of 3

Australian Wool Testing Authority Ltd Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing Accreditation Numbers: 983, 985, and 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.



MICHAEL A. JACKSON B.Sc.(Hons)

Fiona McDonald