

TEST CERTIFICATE

ST-23-04-25-16

Product: Heterogeneous Vinyl Sheet "Saigon", embosscode T,
PU lacquer HyperGuard+, Floor Covering

Producer: IVC Group BV
Nijverheidslaan 29
8580 Avelgem
Belgium

Order: Determination of slip resistance of floor coverings - Methods of evaluation
according to EN 16165:2021-10, Annex B (Shod ramp test - walking on an
inclinable walkway)

Test Report: 2723169


Test Result:

Property	Anti-Slip Class according to EN 16165:2021-10, National Annex NB (informative), Table NB.2
Slip resistance of floor coverings - Methods of evaluation according to EN 16165:2021-10, Annex B (Shod ramp test - walking on an inclinable walkway)	R10

Dresden, 25/04/2023



Head of laboratory



Engineer in charge